



# DUCT LEAKAGE TEST FILL FORM - 2018 IRC

TESTING CONTRACTOR: \_\_\_\_\_ MECH CONTRACTOR: \_\_\_\_\_

Permit Number \_\_\_\_\_ Address: \_\_\_\_\_ Lot: \_\_\_\_\_

Floor Plan/Model \_\_\_\_\_ Sq Ft of Conditioned Space: \_\_\_\_\_

Select one:  Post Construction Test Max leakage 4 cfm/100SF  Rough-in Test w/AC installed Max leakage 4 cfm/100sf  Rough-in Test w/No AC Max leakage 3 cfm/100sf

Area Served: \_\_\_\_\_

Building Inspector Present: YES \_\_\_\_\_ NO \_\_\_\_\_

---

---

## Duct Blaster Test

| Ring# | Total Pressure Min: (25 pa) | Total Leakage Test (CFM): | Allowable Leakage (CFM) |
|-------|-----------------------------|---------------------------|-------------------------|
| _____ | _____                       | _____                     | _____                   |

Tech Name \_\_\_\_\_ Date: \_\_\_\_\_

Signature: \_\_\_\_\_

*Please submit Duct Leakage Test Forms in person at City Hall, 2nd Floor, Community Development or one of the following methods:*

**Mail:** City of Yuma - DCD-Building Safety Division  
One City Plaza  
Yuma, Arizona 85364

**Email:** [permits@yumaaz.gov](mailto:permits@yumaaz.gov)  
**Email:** [sahara.martindelcampo@yumaaz.gov](mailto:sahara.martindelcampo@yumaaz.gov)  
**Email:** [erika.peterson@yumaaz.gov](mailto:erika.peterson@yumaaz.gov)