

Requirements for stocking certificate

The following is a list of the requirements to be met prior to stocking.

Building requirements

1. Plans for the racking to be submitted and approved by the city, and any required anchorage of the racking must be complete and approved.
2. The building needs to be substantially complete. There should only be minor construction being performed in the building. Overhead work shall not be permitted.
3. All electrical work should be complete. This means all panels are to be complete, with dead fronts and covers installed. All wiring to be terminated, and all receptacles and switches installed. Also the main service gear is to be installed and if applicable, the main GFCI breaker be tested per N.E.C. section 230-95. There shall be a responsible party designated for the control of the electrical equipment, and any incomplete electrical shall be terminated and locked out.
4. All emergency lighting and exit signs are to be installed and tested.
5. All exit doors are to be installed with appropriate hardware, and all exit paths are to be unobstructed.
6. Fire sprinkler system shall be installed, inspected, and approved as functional.
7. Parking area to be complete for the personnel installing racking or stocking.
8. All fire extinguishers shall be installed as indicated by the approved plans and the current adopted fire code.
9. Restroom facilities shall be complete, inspected and approved.
10. Disinfection of the potable water system throughout is to be complete and bacteria testing documentation provided.

Note: This list may not be all inclusive of all the requirements needed. As circumstances dictate there may be additional requirements needed.

Randy Crist CBO
Building official

